

455G.32 E-85 gasoline compatible infrastructure — compliance requirement.

1. A retail dealer shall not install, replace, or convert gasoline storage and dispensing infrastructure used to store and dispense ethanol blended gasoline classified as E-15 or higher, unless the installed, replaced, or converted gasoline infrastructure is capable of storing and dispensing ethanol blended gasoline classified as E-85.

2. The infrastructure must be all of the following:

a. Listed as compatible for use with ethanol blended gasoline classified as E-85 by an independent testing laboratory or as approved by the manufacturer.

b. Approved by the department or state fire marshal subject to conditions determined necessary by the department or state fire marshal. The department or state fire marshal may waive the requirement in paragraph “a” upon satisfaction that a substitute requirement serves the same purpose.

[2022 Acts, ch 1067, §29, 31](#)

Referred to in [§455G.31](#)

Section effective January 1, 2023; 2022 Acts, ch 1067, §31

NEW section